

MONITORTM XL

Integrated Security Management

LCD Keypad User's Guide

V1.0

*Attention: Security Representative,
Please give this guide to the customer before beginning work on the system.*

VEREX

Contents

Welcome	1
The Monitor xL™ LCD Keypad.....	2
Alarms, Turning Protection On and Off	5
Alarm Monitoring Features	6
Audible Keypad Tones	6
Sirens	7
Dealing with Alarms (what to do if the keypad is beeping)	7
Silencing a False Alarm.....	7
Using the Emergency Keys	8
Worklate: Extending the Scheduled Closing Time.....	8
Suspending Schedules for an Area or Areas.....	9
Turning Protection ON, STAY, or Viewing the Present Arming-Level.....	9
Turning Protection Off	10
Turning Protection On by Area Groups, a Group of Areas or Individual Areas.....	10
Turning an Area's Protection ON and OFF using an Access TOKEN	11
UK System Operation.....	11
UK and European System Operation	12
Checking Status and Controlling Items	13
Status and Control Features.....	14
Using the Function Keys.....	14
Checking the System Status (monitored conditions for a system control unit)	14
Checking the Status of Sensors (Points) and Areas.....	15
Bypassing a Faulty Sensor.....	15
Checking Status or Controlling Readers or Doors.....	16
Checking the Status or Controlling an Elevator Reader	17
Checking the Status of an Application Module (POD)	17
Administration and Maintenance Tasks	19
Changing Your Own PIN	20
Adding a User to the System.....	20
Default Authority Settings	21
Viewing or Changing Settings for a User.....	22
Deleting a User.....	24
Setting the Date and Time.....	24
Viewing the History	25
Printing the History Log	26
Changing the Printed History Language.....	26
Testing Monitored Sensors (Performing a Walk Test).....	27
Testing Panic Buttons (Performing a Hold-up Test)	28
Testing Sirens (System Test)	28
Reference Topics	29
System Information.....	30
Residential Fire Safety / Evacuation Plan.....	32
Arming Station Reference.....	34
Wireless Keypad Reference	37
Error Messages and Trouble Indications	38
Things to Do to Prevent False Alarms	39
Index	40

About This Guide

This guide provides details on performing various tasks in a MONITOR xL™ system using an LCD keypad.

To locate a desired topic, refer to the table of contents (near the front of this guide), or the Index (near the back of this guide).

Tip: The bottom of each odd-numbered page also gives an indication as to your general position within this guide.

Also See (Related Documents)

For details on using the Director software, refer to the on-line help or User's Guide provided with the software.

Copyrights and Trademarks

™ Monitor xL is a trademark of CSG Security Inc./Sécurité CSG Inc.

™ Pentium is a trademark of Intel Corporation
™ © Microsoft, Windows, Windows2000, and Windows XP, are trademarks or registered trademarks of the Microsoft Corporation.

© Copyright 2005
CSG Security Inc./Sécurité CSG Inc.
All rights reserved.

Disclaimer

In the interests of ongoing improvement in quality and design, we reserve the right to change product specifications without prior notification. All software, firmware, drawings, diagrams, specifications, catalogues, literature, manuals and other materials relating to the design, use, and service of related products shall constitute the proprietary information of the manufacturer.


Welcome

Dear Customer,

- It is recommended that you review the different operating procedures in this guide while your system is being installed. Ask your Security Representative to explain any questions that you may have about the various topics.*
- It is important to check the section at the back of this booklet that will list information about your alarm system named “Reference Topics”. Ask your Security Representative to supply the information that should be entered into this section.*

Thank-you.

The Monitor xL™ LCD Keypad



The MONITOR xL LCD (liquid crystal display) keypad provides an integrated 2-line display and multi-function backlit keypad. (The keypad is hidden behind a hinged access cover.)

What You can do with the LCD Keypad

MONITOR xL™ LCD keypads provide a convenient local interface that allows:

- Turning protection on and off;
- Checking status of items;
- Controlling / commanding items;
- Performing administrative tasks;
- Some models can act as a card reader to permit access to locked doors.

Keypad Display and Buttons

The display is your 'window' into the MONITOR xL system.

When you enter your user ID and/or PIN, you will be given access to all menus and features as assigned through your user authorities.

Buttons under the Display Screen

The buttons directly under the display screen allow selecting associated items on the display screen. This means the item displayed on the screen above each button.

Like the rest of the keypad, these buttons are backlit for use in poor lighting conditions.

The Numeric Keypad

The main keypad (in the bottom-left portion of the unit) provides a convenient way to enter numbers, and letters as well (when applicable).

The X Key

This is the "escape" key, which allows you to return to a previous screen, or exit from a menu altogether (log out).

The ◀ arrow ▶ Keys on the Keypad

These keys allow selecting different items and topics. When available, the left ◀ or right ▶ arrow keys will appear on-screen.

Emergency Keys and Programmed Function Keys

Pressing a number and the *f* key at the same time will perform the action as programmed for that key-sequence. The emergency keys at the bottom of the keypad each transmit a specific emergency message (to the central monitoring station).

For more information on the emergency keys, refer to "Using the Emergency Keys" in the "Alarms..." chapter.

For details on the programmable function keys, refer to "Using the Function Keys" in the "Status & Control" chapter.

If You Are Being Forced to Enter Protected Premises

A duress (panic) alarm is triggered when you enter your PIN with the last two digits reversed. This can be done at reader keypads, system LCD keypads, and Suite Security LED keypads.

Normal PIN Example: 1 2 **3 4**

If being forced to Enter: 1 2 **4 3**

This feature will be available unless it was disabled by your service technician when the system was initially set up.

Logging Into the Keypad (User ID and/or PIN)

NOTE: Your Security Representative will supply you with your User ID and PIN number for pressing into the keypad and logging in to the system.

(The default Master user ID and PIN is: e.g. ID: 01 or 001, PIN: 7793)

"Logging In" provides you with access to the features of the LCD keypad. To log in:

Open the keypad cover, and press in your user ID number and/or PIN number as indicated on the display.

Welcome
Enter ID: _ _ _

Your Name Appears
Enter PIN: _ _ _ _

When finished viewing or entering items, you can use the **X** key to exit (press multiple times as needed--until the "login" screen appears).

Tip: You will also be logged out automatically if you do not press any keys for approximately one (1) minute.

Overview of Screens (Topics)

When logged in, you will see only the topics that you have the authority to use. Some or all of the following topics will be available:

Selecting a Topic: Press the "►" key until your desired topic appears on-screen. Then press the key directly under your topic to select it.

Off // Stay // On:

Push ► for Menu
↓ Stay ↓ On

The first screen that you'll see allows you

to arm or disarm the area(s) as desired, or to access other topics.

Only two of arm/disarm selections will appear at a time—depending on the present arming-state of the area(s).

Off: all intrusion protection fully off.

Stay: partial protection. Internal motion detectors disabled. Only perimeter protection on. For users to remain inside the protected area.

On: all protection fully on. No one remaining in the protected area.

Status: This allows checking the status of various items in the system, or commanding items into different states.

Please ignore uncommon status screens that may show up like "Comms, Modem, Licns". They are for a service technician's purposes.

Bypass: This allows bypassing faulty sensor(s) so the system ignores them, and/or to allow arming the system.

History: This allows viewing a record of the tasks that users have performed (disarm areas, bypass sensors, etc.)

My PIN: This allows the person who is logged in to change their password.

Users: This allows adding or deleting 'users' from the system, or viewing or editing settings for specific users.

A "User" is a person who has the authority to login to system keypads, and/or to gain entry at access-controlled doors.

Test: This allows testing different aspects of the system.

Verify: This allows a person to prove they are present. This lets a monitoring facility know that you are present after accidentally tripping a sensor, and/or silencing a false alarm.

Schedule: This allows extending the scheduled closing time for an area (the "work-late" feature), or suspending a schedule altogether.

Arm/Disarm: Re-enters the screen for turning the system to Off, Stay or On.

Time: This allows changing the time and/or date for a system panel.

Keypad Entry Basics

Use the buttons directly under the display screen when the arrow "↓" beside desired subjects on the screen is pointing down to the corresponding keypad buttons.

The ◀ and ▶ buttons allow you to view additional topics--when available. ("◀" and/or "▶" will appear on the display screen to indicate these keys can be used).

Use the "X" escape key when finished with your present menu / topic to return to the main screen or back out of inner screens.

Entering Letters (e.g., for a user's name)

The numeric keypad allows entering numbers--and letters as well--for items that support this.

When required, press the specific key multiple times until the desired letter appears:

Pressing "2" multiple times produces: **2 A B C** on the screen.

Pressing "3" multiple times produces: **3 D E F** on the screen.

...etc. (look for the letters on each key).

Tip: The " " on the 0 key (zero) represents a space.

Alarms, Turning Protection On and Off

Alarm Monitoring Features

Depending on how the system is set up, specific alarms may be indicated by any of the following items:

- An alarm message will appear on specific keypad(s);
- Keypad 'sonalerts' (beepers) may sound;
- A local siren may be triggered;
- An alarm message may be transmitted to a monitoring station (and/or to a management PC running the Director software);
- A programmable "output" may be triggered (this can cause a horn to sound, or perform any other type of automated 'switching' function);
- A numeric pager may be called to let the wearer know that a specific type of alarm has occurred.

These actions can be fully customized for each type of event--for each arming level that the system can be in at any time (Off, Stay or fully ON).

Audible Keypad Tones

Visual indications (lights and LCD menu prompts) are complemented by audible tones.

When Arming and Disarming



Slow turning on and off beeping.

Entry and Exit Delay Tones



Quick turning on and off beep.

Error and Warning Tones


These tones are heard upon errors in keypad entry, selection of wrong PIN numbers and to indicate that there was an alarm (upon entry) during the last armed period.



Very fast beep.

Trouble

This tone is heard when the system has a problem (e.g. cut phone line) or the system goes into alarm.



Steady continuous tone.

Fire Alarm



A repeating tone that turns on for 5 seconds off for 5 seconds. After this happens 3 times there is a delay and the same sequence repeats.

Confirmation of PIN/ID & PIN Entry



Single short beep

Chime (see page 31 for Chime Operation)

When the chime feature is turned on and a door is opened.



Three short low level beeps.

Sirens

Conventional Siren
Fire Alarm: Intermittent Tone (the same as a Fire Alarm in the previous keypad tone details).
Burglar Alarm: Steady Tone.

Voice Siren (optional)
Fire Alarm: Steady tone, followed by optional voice Fire Alarm Message. (e.g. "FIRE! FIRE! ... Leave Immediately!")
Burglar Alarm: On and off tone, followed by optional voice Burglar Alarm Message. (e.g. "Intrusion! Intrusion! ... The police have been called, leave immediately").

Dealing with Alarms (what to do if the keypad is beeping)

If an alarm occurs, you must first decide if it is a valid alarm (break-in, battery failure, etc.), or a false alarm. If a valid alarm occurs, be sure to notify the appropriate persons, and/or take steps to either deal with the item yourself--if appropriate, or get yourself and others to safety.

Silencing a False Alarm

An authorized user can **Cancel** a false alarm, disarm the system and inform the monitoring station not to dispatch the respective emergency service.

This feature may not be available in all areas. Consult your local security representative for more information.

The following steps assume that you have accidentally triggered a false alarm. If an alarm has been generated, the LCD display will show the alarm, and the keypad 'sounder' will probably also be making a steady tone.

Steps:

1. Enter your user ID and/or password to log into the keypad.

!! In Alarm !! Enter ID: _ _ _

2. Select **Yes** to silence the alarm.

Silence System? ↓Yes ↓No View↓

3. Select **Yes** again to verify who you are.

Verify User? ↓Yes ↓No

4. Enter your PIN when prompted. This will signal the monitoring facility that you want to cancel the false alarm.

To Verify User Enter PIN: _ _ _ _

5. To disarm area(s), select "**Off**".

Push ► for menus ↓Off ↓Stay

6. Select **Yes** to turn all areas off, if desired.

All Areas Off? ↓Yes ↓No

7. If there was a false alarm, the following screen will appear.

Area XX Had an Alarm

8. Select **Ack** to acknowledge the alarm and disarm the system.

xxx: <i>Sensor Name</i> Status ↓Ack

XXX: refers to the number for the monitored sensor (input point) that was in alarm.

9. Press this key to perform another function.

Disarming... ↓Next Function


To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

The entry tones will now stop sounding and the selected areas are now fully disarmed.
If the Verify option is used, it must be done within 1 minute of the false alarm occurring, for the station to acknowledge the signal.

Using the Emergency Keys

There are three emergency keys that will cause an emergency alarm. This will be transmitted to the monitoring station, and may also turn on a local alarm, a programmable output, and/or cause a numeric pager message to be sent (depending on how the system is set up).

To transmit an emergency alarm, press the button on **both sides** of the specific symbol at the same time.



Alert Keys



Fire, press the “F” function key (discussed in “Using the Function Keys”) and the left arrow key ◀ at the same time.



Panic/Police Alarm, press the left and right arrow keys ◀ ▶ at the same time.



Emergency (Non medical), press the left arrow key ▶ and the “X” Escape key at the same time.

Alert Keys are only available if they have been ordered by you and supplied by your Security Representative.

Worklate: Extending the Scheduled Closing Time

A **Schedule** represents when e.g. a commercial system is open for normal business hours. If the scheduled closing time is approaching when the protection is turned on, and you wish to remain in the area, you can extend the 'closing' time.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: ___
```

2. Press the ◀▶ arrow keys until you see "Schdule". Then select **Schd**.

```
Menu Options
◀Schd ▶ ↓Ok
```

3. Select **Schd** to change the Schedule for the selected area (e.g. Office) or select **Next Area** to select a different area.

```
AreaName.....Off
↓Schd ↓Next Area
```

4. Select **WorkLate** to change the closing time for your selected area.

```
Close -> 09:30pMo
↓Worklate Susp↓
```

5. Select "+" or "-" to adjust (Adj) the closing time as desired.

```
..until 17:30pFr
↓Ok ↓+ Adj -↓
```

The "+" and "-" (Adj) keys adjust the closing time by increments of 30 minutes.

6. Once the scheduled closing time is correct, select **Ok**.

```
..Until 17:30pFr
↓Ok ↓+ Adj -↓
```

To return to the main screen (log out), press the “X” escape key a few times, or let the system time-out (1 minute).

An authorized user may only change the WorkLate Schedule for the current day. 15 minutes before a Schedule ends, the system will chime indicating that a scheduled closing is pending. At this stage, an authorized user may change the WorkLate time to suspend the system closing until a specified time.

Suspending Schedules for an Area or Areas

A schedule can be blocked altogether if you do not want a scheduled closing to occur.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

Welcome
 Enter ID: ___
2. Press the ► keys until you see "Schedule". Then press the key under "Schedule" to select it.

Menu Options
 ◀Schedule ▶ ↓Ok
3. Select **Schd** to suspend the Schedule for the selected area (e.g. Office) or select **Next Area** to select a different area.

Area.....Off
 ↓Schd ↓Next Area
4. Select **Susp** to suspend the Schedule for the selected area.

Close by 17:30pMo
 ↓Worklate **Susp**↓
5. Select **Ok** to suspend the schedule and return to the main screen. Select **Resume** to reinstate the schedule.

Suspended
 ↓Ok Resume↓

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

WARNING: A Schedule will remain suspended indefinitely until "Resume" is selected .

Turning Protection ON, STAY, or Viewing the Present Arming-Level

With the appropriate authority, you can arm and disarm the system, or specific area(s) using an LCD keypad.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

Welcome
 Enter ID: ___
 2. Select the button for your desired protection level.

Push ► for menus
 ↓Stay ↓On
- If all areas are currently OFF, only STAY and ON are shown. If STAY is not an authorized function, only ON will be shown.

The "Stay" arming-level refers to the perimeter sensors being monitored, but not the interior ones. This is typically used when someone is inside the facility or protected area.
3. Select **No** to choose an Area to view or change (or **Yes** for all areas ON).

All Areas ON?
 ↓Yes ↓No
 4. Press the left button to set the arming-level. Select **Nxt** to choose a different area, or select **Done** to exit.

AreaName.....Off
 ↓On ↓Nxt Done↓
 5. Select **OK** to confirm. (**Review** allows you to change your mind.)

Area(s) to....ON
 ↓OK ↓Review
 6. If points are currently bypassed, in tamper, in alarm, or not Ok, the following screen will appear when you are attempting to arm an area (to Stay or ON).

Pts in Bypass!
 ↓Ok? ↓View
 7. Select **Ok?** to arm the system, or **View** to list points that are currently not Ok.

WARNING: Selecting OK will arm the system with point(s) not secure.

Select **View** to view points that are currently bypassed or not Ok. At this time the system will indicate points that are not OK and force you to either bypass or secure these points in order to arm the system.

```
Points not Ok!
↓View
```

```
AreaName.....Off
↓Pts ↓Next All↓
```

Select the desired topic:

- **Pts:** Bypassable points (sensors) in the displayed area;
- **Next:** Show the next area;
- **All:** All bypassable points regardless of area.

```
xxx:► Sensor Name
Status ↓Bypass ↓?
```

When a point/sensor is displayed, you'll have these options:

- "**◀▶**": Press the arrow keys to scan through the sensors (points) in the system (or the selected area);
- **Bypass:** Select this for the system to ignore (bypass) the selected sensor.
- "**?**" jumps to the next point that is not OK.

```
Arming...Bypass
↓Next Function
```

Once all points have been bypassed or secured, the system will automatically arm.

```
Area(s) arming
Please Leave
```

After arming (On), leave immediately by the designated exit route!

The tone you will hear is a reminder for you to quickly leave the area or premises. During the last 15 seconds this intermittent tone will speed up. The exit tones will now stop sounding and the selected areas are now fully armed.

Turning Protection Off

1. When you have entered the area with THE protection ON, the keypad will beep and the screen will display:
2. Enter your user ID and/or PIN to log into the keypad.

```
To Disarm
Enter ID: ___
```

3. This screen will display, to choose turning the area fully off or put in Stay for partial protection.

```
Push ► for menus
↓Off ↓Stay
```

4. After making your selection, this screen will ask if the protection for all areas should be changed, if there is more than one area. If "No" is selected, this screen will display the current condition of the available areas e.g. "On" and selections for that area. Selections for other areas are displayed by pressing "Nxt" or just change the protection level for the area you are in. Pressing the button below "Done" will process the selections you made.

```
All Areas Off?
↓Yes ↓No
```

```
Area 1.....On
↓Off ↓Nxt Done↓
```

Turning Protection On by Area Groups, a Group of Areas or Individual Areas.

Check with your Security Representative to have this feature added to your system. You must have the proper Authority to control additional protected areas.

1. Enter your user ID and/or PIN to log into the keypad.
2. Select the button for your desired protection level. Selecting "Stay" will supply selections for the areas separately. Selecting "On" will supply the special way to turn area protection on.
3. Select **Yes** if an authorized user has been assigned with the authority level to turn on a certain group or groups of areas at the same time.
4. If authorized, select **No** to choose individual Area Groups or Areas to turn on.

```
Welcome
Enter ID: ___
```

```
Push ► for menus
↓Stay ↓On
```

```
All Areas ON?
↓Yes ↓No
```

```
Choose Area by?
↓Group ↓Area
```

Turning ON an Area's Protection using an Access TOKEN



Check with your Security Representative to have this feature added to your system. You must have the proper Authority to control additional protected areas.

1. Place and hold the token in front of the keypad within 2 -3 inches (78mm).
2. The exit delay will start and the keypad will sound its exit delay beeps.

Welcome Enter ID: ____

Arming... ↓Next Function

Turning Off an Area's Protection using an Access TOKEN

1. If you have entered the area with protection on, the keypad will beep and the screen will display:
2. Repeat holding the token in front of the keypad within 2 -3 inches (78mm).
3. The screen will display:
Protection will be off.

To Disarm Enter ID: ____

Disarming... ↓Next Function

UK System Operation

The following is required to ensure conformity with the ACPO, DD243:2002 Standard.

If this screen displays after disarming ... the system has had a Confirmed Alarm and the following procedure must be done:

Confirmed Alarm! Enter ID: ____

Resetting Confirmed Alarms

Once a confirmed alarm occurs at a site, the user will be able to disarm and silence the system. The confirmed alarm strobe display, if it is part of the system's equipment, will also turn off. However, arming will be blocked until reset by an Engineer during a service call in the following manner:

1. The main panel cabinet must be opened to activate the 'tamper sensor'
2. The system will generate a tamper alarm; the authorized user must first silence this.
3. Next, the Service user ID and Pin must be entered followed by the ID and Pin of the authorized user.
(Master end user ID and PIN default: e.g. ID: 01 or 001, PIN: 7793)
4. Select "Reset Confirmed Alarm".
5. Close the main panel cabinet to secure the tamper sensor.

If there is an attempt made to arm the system and this reset procedure has not been done, this screen will appear momentarily...

!! Cannot Arm !! Confirmed Alarm!

External Arming Button

When attempting to arm the system and exiting the protected area the "external arming button" must be pressed. Failure to do so will result in a "Failed to Exit" condition. The protection will disarm at the end of the arming delay and a failed to exit report will be logged in the system's History log.

UK and European System Operation

Restoring Tamperers

Once a tamper condition occurs it will be logged in the system's History log. Any authorized users can silence tamperers

Was in Tamper!
Enter ID: _ _ _

however; the following system message will scroll on the LCD display to indicate that a tamper condition had occurred...

This message will only appear when the tamper condition has been restored. The yellow "trouble" light on the keypad will also turn off.

1. This message can only be cleared during a service call in the following manner.
2. The main panel cabinet must be opened to activate the 'tamper sensor'
3. The system will generate a tamper alarm; the authorized user must first silence this.
4. Next, the Service user ID and Pin must be entered followed by the ID and Pin of the authorized user.

(Master end user ID and PIN default: e.g. ID: 01 or 001, PIN: 7793)

This screen message will display to prompt for the master

2nd Service User
Enter ID: _ _ _

authority user to enter their ID and Pin.

After the reset procedure has been completed, the system Status can be checked to ensure that the only tamper condition still displaying is the open main panel cabinet.

5. Close the main panel cabinet to secure the tamper sensor.

Arming / Disarming Conditions

If at the time of arming, certain system faults are present, arming will be blocked.

The red armed light on the keypad will only stay on for 30 seconds from the time of any arming.

This is to prevent the condition of the system from being easily visible.

To view the armed state of the system, log in from the "Enter ID:" screen. If all areas are ON this screen will display:

All on Menu ▶
↓Off ↓Stay

If one or some areas are armed this screen will display:

Partially Armed ▶
↓Off ↓Stay

If a trouble condition occurred since the last arming, this screen will display on disarming...

When this screen is acknowledged (Ack) the problem condition can only be seen by checking system Status. If fault conditions are present, than arrangements should be made to have them corrected.

System Fault or
Tampered ↓Ack

Remote Reset

For customers who would rather reset the ACPO alarm themselves, instead of a service/engineer person attending and doing it.

- When the ACPO alarm occurs, the LCD keypad screen will display a 6 digit code.
- The customer notifies the monitoring station with this number.
- The monitoring station enters the number in this program's "Customer Input:" box and generates a response 6 digit number.
- The monitoring station gives this response number to the customer who enters it into the keypad and can reset the ACPO alarm.

Checking Status and Controlling Items

Status and Control Features

NOTE: Status will display certain options e.g. “Comms, Modem, Licns” that will not appear familiar because they are not covered in this publication. These options should be ignored by the end user because they are for a technician’s use only.


Using an LCD keypad, you can:

- Check the status of various items in the system and view the present arming-level of desired area(s).
- Bypass faulty sensors to allow arming the system and/or specific area(s);
- Command doors to Unlock, relock, or change operating characteristics;
- Use the function keys to perform pre-programmed signalling and/or switching functions.

Using the Function Keys

LCD keypads provide 10 function keys that can perform various signalling and/or switching functions. **Consult with your security representative to learn what the ones you may have ordered do.**

To use function key 1, 2, 3, 4, or 5, simply press and hold the “F” key, and press the desired number at the same time.



For function keys 6, 7, 8, 9, and 0, a user with function-key authority may need to enter their ID/PIN numbers to be allowed to use these function keys.

This requirement can be assigned as necessary to any areas. Check with your security representative.

To log in, open the keypad cover, and key in your user ID number and/or PIN number as indicated on the display.

```
Welcome
Enter ID:  _ _ _
```

```
Your Name Appears
Enter PIN:  _ _ _ _
```

Then press and hold the “F” key, and press the desired number at the same time.

Checking the System Status (monitored conditions for a system control unit)

The system status feature shows the status of all conditions such as (tamper, low battery, etc.) that are being monitored for the control unit associated with your keypad.

These items may also be referred to as “Equipment” conditions.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID:  _ _ _
```

2. Select ► to access other functions.

```
Push ► for menus
      ↓Stay ↓On
```

3. Use the ◀ and ▶ arrow buttons to scan through the listed items. When “Status” appears, press Ok.

```
Menu Options
◀Status ▶ ↓Ok
```

4. Use the ◀ and ▶ arrow buttons to scan through the listed items and press Ok.

```
Status Options
◀System ▶ ↓Ok
```

To return to the main screen (log out), press the “X” escape key a few times, or let the system time-out (1 minute).

For details on the possible status messages, refer to “Error Messages and Trouble Indications” in the reference section near the back of this guide.

Checking the Status of Sensors (Points) and Areas

The Points-status feature allows checking the status of sensors in the system (and viewing the arming-level for areas).

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: ___
```

2. Select **►** to access other functions.

```
Push ► for menus
      ↓Stay ↓On
```

3. Use the **◀▶** arrow buttons to scroll the items

```
Menu Options
◀Status ▶ ↓Ok
```

4. Select **Points** press Ok.

```
Status Options
◀Points ▶ ↓Ok
```

5. Select the desired topic:

- **Pts:** Protection Points (sensors) in the displayed area;
- **Next:** Show the next area;
- **All:** All points regardless of area.

```
AreaName.....Off
↓Pts ↓Next All↓
```

When a point/sensor is displayed, you'll have these options:

```
xxx: Sensor Name
Status ↓Bypass ↓?
```

- **"►":** Press the right arrow key to scan through the sensors (points) in the system (or the selected area);
- **Bypass / Delbyp:** Select **Bypass** to have the system ignore the sensor (or **"Delbyp"** to remove a "Bypass" that is in effect). [Also see: Bypassing a faulty sensor, to follow.](#)
- **"?"** jumps to the next point that is not OK.

Bypass appears only for points that are bypassable.

An Entrance Door can not be bypassed.

An area's sensor cannot be bypassed if the area is ON.

If all points are OK, you will see an "All Secure" message.

```
All points in
area are secure
```

To return to the main screen (log out), press the **"X"** escape key a few times, or let the system time-out (1 minute).

Bypassing a Faulty Sensor

If the system (or a specific area) needs to be armed with a faulty or insecure sensor, you will need to bypass the problem sensor.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: ___
```

2. Scroll the **◀▶** left and right arrow keys until "Bypass" appears on the display. Press Ok

```
Menu Options
◀Bypass ▶ ↓Ok
```

An area's sensor cannot be bypassed if the area is ON.

You can also bypass sensors through the Points-status screens (see the preceding topic for details).

3. Select the desired topic:

```
AreaName.....Off
↓Pts ↓Next All↓
```

- **Pts:** Bypassable points (sensors) in the displayed area;
- **Next:** Show the next area;
- **All:** All bypassable points in all areas.

4. When a point/sensor is displayed, you'll have these options:

```
xxx: Sensor Name
Status ↓Bypass ↓?
```

- **"►":** Press this key to scan through the sensors (points) in the system (or the selected area);
 - **Bypass / Delbyp:** Select **Bypass** to have the system ignore the sensor (or **"Delbyp"** to remove a "Bypass" that is in effect).
 - **"?"** jumps to the next point that is not OK.
5. If all bypassable points are secure, you will see a related message.

```
No bypassable
points insecure
```

To return to the main screen (log out), press the **"X"** escape key a few times, or let the system time-out (1 minute).

Checking Status or Controlling Readers or Doors

The Door status screens allow persons with the appropriate authority to:

- Check the status of doors in the system (or specific areas);
- Command doors to unlock, relock, or change operating characteristics.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: _ _ _
```

2. Select ► to access other functions.

```
Push ► for menus
      ↓Stay ↓On
```

3. Use the ◀ ► left and right arrow buttons to scroll the items

```
Menu Options
◀Status ► ↓Ok
```

4. Select **Doors** and press Ok.

```
Status Options
◀Doors ► ↓Ok
```

(Condo: Suite Security)

5. Select the desired topic:

```
AreaName . . . . Off
↓Door ↓Next All↓
```

- **Door:** For doors in the displayed area;
- **Next:** Show the next area;
- **All:** All doors regardless of area.

6. Now select **Door**, or **Readers**, as desired:

```
D0x: Door Name
↓Door ↓Readers
```

- "►": Press this key to scan through the doors in the system (or the selected area);
- **Door:** Door status, or commands to unlock or relock the door, or lockout (or reinstate) all cards;
- **Readers:** Will indicate the current reader conditions in the system and lets you change the condition (e.g., Card+PIN, dual custody, etc.).

7. If you selected **Door**, the door state will be shown, and you'll have these options:

```
D0x: Door Name
↓DoorState ?↓
```

- "►": Press this key to scan through the doors in the system (or the selected area);
- **Select the door state:** Then, you can use the ◀ ► left and right arrow buttons to access a command (and press the key under the command to select it);
- "?" jumps to the next door that is not OK.

8. If you selected **Readers**, the reader mode will be shown, and you'll have these options:

```
D0x: Area Name
↓Cmd RdrModes
```

- "►": Press this key to view the second reader for the selected door (if applicable);
- **Cmd:** Provides access to the reader mode selections that follow.

9. Your **Cmd** choices are shown below:

```
R0x: Area Name
↓Mode ↓Card ↓Lock
```

- **Mode:** Access modes including "Normal", "Dual Custody" (two users/access cards needed to enter), and "Escort" (a user identified as a "Escort" must present their card first, then a 2nd person with a valid card);
- **Card:** This includes various card-mode selections (i.e., card and/or UID and PIN);
- **Lock:** This allows you to lockout or reinstate card-access at this reader.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

Checking the Status or Controlling an Elevator Reader

For systems that include elevators, the "Status" menu will include an "Elev" selection for elevators and their associated readers. The available selections will be the same as for standard readers, as described in the preceding section.

Attention: All floor status and control functions are available only through the Director software. It is recommended that all elevator reader status and control tasks be performed through the software as well.

Exception: Checking a specific aspect of an elevator reader can be performed through the keypad (such as checking if it is in Card Plus PIN mode), but you will have to log in at a Director software PC to see if the floors are secure.

Checking the Status of an Application Module (POD)

You can check the status of any "application" modules in the system. (An application module provides increased functionality such as Printer capability.)

POD (definition): "Module" - a controller that e.g. connects a Printer to the system.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

Welcome
 Enter ID: _ _ _
2. Select ► to access other functions.

Push ► for menus
 ↓Stay ↓On
3. Use the ◀ ► left and right arrow buttons to scroll the items.

Menu Options
 ◀ **Status** ▶ ↓Ok
4. Select **App** to view status of an Application Module. Press Ok.

Status Options
 ◀ **App** ▶ ↓Ok
5. Select **Yes** to view the status of the indicated module (e.g. "HSC" for Printer), or use the ► right arrow button to select another module.

ModuleName/Type ►
 ↓Yes ↓No
6. Select **HSC** and then **Printer** to view the status of the Printer.

Pod Status
 ↓Printer
7. The status screen will indicate if the system device is Ok or disabled and any device related information.

PRN(printer):OK
 POD:OK

Select **Next** to view status of the next module.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).







Administration and Maintenance Tasks

Changing Your Own PIN

The person who is logged in can change their PIN number at any time.

Steps:


1. Enter your user ID and/or PIN to log into the keypad.

2. Press ► to scroll to the PIN option.

3. Select **My PIN** to change your PIN. Press Ok.

4. Enter your new 4-digit or 5-digit PIN.


TIP: You can use the letters on the keypad to 'spell' a word as a reminder of your PIN.

Re-enter the new PIN a second time when prompted for this (this helps to protect against typing errors).

Note: The last two digits of the PIN can not be identical. Do not use consecutive numbers such as 1234. For security reasons, duplicate PINs are not allowed on systems with a PIN only user code. If the message "PIN not allowed" appears, select a different PIN.

The "PIN changed" screen displays and then returns to the system standby screen.







Adding a User to the System

New users can be added to the system as needed.

A User is a person who can use system keypads, and/or gain entry at access-controlled doors.

Steps:

1. Log into the keypad by entering your user ID and/or PIN as indicated on-screen.

2. Press ► until "Users" appears, & press Ok.

3. Enter an available user number (and select **Ok**), or select **Ok**, and then press ► until a user number appears with "Add" (instead of Edit and Delete).

4. Undfnd (Undefined) Select **Add**.


?: In this screen, "?" refers to systems with Suite Security keypads (allows viewing the user's Suite related abilities for the selected user number). **Note:** Suite Security assignments for a user are set up through the Director software.

Refer to the details that follow while working with any of the listed topics:

Aut: Use the **Next** and **Prev(ious)** buttons to select an authority profile for the user. (Select **Ok** when finished).



This determines what doors the user can enter (and at what time of day), and the tasks they will be able to perform at system keypads. This selection cannot be **Undfnd** (Undefined).

Consult your Security Representative to make changes to the authority levels.

Default Authority Settings	Master	Supervisor	Employee	Worker	Cleaner
<u>Intrusion</u>					
Emergency Off	✓	✓			
Isolate	✓	✓			
Bypass	✓	✓			
Auto-lift Bypass	✓	✓			
Test	✓	✓			
Service Test	✓				
Silence Alarm	✓	✓	✓		✓
Status	✓	✓	✓	✓	✓
History	✓	✓			
Function Key Authorization	✓	✓			
Work Late	✓	✓	✓		✓
Suspend Schedule	✓	✓			
On	✓	✓	✓	✓	✓
Off	✓	✓	✓		✓
Stay	✓	✓	✓		✓
Auto Disarm to Off	✓	✓			
Auto Disarm all Areas	✓	✓			
<u>Access</u>					
Access when Area is Off/On/Stay	✓	✓	✓	✓	✓
Escort		✓			
Master Override	✓				
Reset Door Alarm	✓	✓			
Door Command	✓	✓	✓		
Class A	✓	✓	✓	✓	✓
Class B	✓	✓	✓	✓	✓
Class C	✓	✓	✓	✓	✓

System / Suite (Condo):

For systems with Suite Security keypads, this screen allows accessing the **System** authority screen (same as the previous **Aut** "Authority") or, the **Suite Security** (Condo) authority screen.

```
0xx UserName
↓System ↓Condo
```

```
0xx AuthProfile
↓Ok ↓Next ↓Prev
```

Tip: Press the "X" escape key if you do not want to use this screen.

Use the **Next** and **Prev** buttons to select a Suite Security authority profile for the user. (Select **Ok** when finished).

Suite Authority of "Undfnd": This is a reserved suite user (that can be edited by a user with Suite "Master" authority).

Suite Security Authority assignments for a user are set up through the Director software.

More: Provides access to additional screens.

Name: Use the keypad to enter the user's name, and select **Ok** when finished.

```
↓Ok . . . . .
```

Tip: Check the letters on the numeric keypad. Then, for each letter of the name, press the specific key until the letter appears (e.g., pressing **2** makes a 2, A, B, C; **0** provides 0, Z, _ <space>, Q, etc).

To move to the next letter-position, use the ► right arrow button, or wait 2 seconds. To retype a previous letter, use the ◀ ► left or right arrow keys, and then enter the letter as before.

Card: Enter the card version number (if applicable), and the access-card/token number for this user, and select **Ok** when finished.

```
0xx UserName
↓Ok vv_nnnnnnnnn
```

If card-access (entry at controlled doors) does not apply, leave the card number as "00000000".

Card Version number support is supplied by your Security Representative.

Firmware revisions needed for 9-digit card IDs, or cards with version numbers: Panel firmware ≥ **V3.2**, and door/elevator controller firmware ≥ **V1.5**.

PIN: This allows setting or changing the **Personal ID Number** for this user. (You'll be asked to enter it twice--to help protect against typing errors.)

```
New PIN - - - -
For User 0xx
```

The last two digits of the PIN must be different. Also, do **not** use consecutive numbers like 1234.

Lang / Chal: This screen allows setting the LCD language for this user, and whether or not the "physically-challenged" unlock times and door-held-open times apply to this user.

```
0xx . . Lng:Eng.C:N
↓Ok ↓Lang ↓Chal
```

Select **Lang** to 'toggle' the language, or **Chal** to 'toggle' the "Challenged" setting. When finished, select **Ok**.

Watch the screen for the settings to change. (You will remain in this same screen.)
Lng:Eng means Language is English
C:N means Challenged? - No.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

Viewing or Changing Settings for a User

For an existing user, you can view or edit their settings as desired.

A User is a person who can use system keypads, and/or gain entry at access-controlled doors.

Steps:

1. Log into the keypad by entering your user ID and/or PIN as indicated on-screen.

```
Welcome
Enter ID: _ _ _
```

2. Press ► until "Users" appears, & press Ok.

```
Menu Options
◀ Users ▶ ↓Ok
```

3. Enter the specific user number (and select **Ok**), **or** select **Ok** first, and then press ► until the desired user appears on-screen.

```
0xx Select User
↓Ok
```

4. Select **Edit**.

```
0xx ▶ UserName  
↓Edit ↓Delete ↓?
```

↓?: refers to systems with Suite Security (Condo) keypads (allows viewing the suite user assignments for your selected user number). **Note:** Suite user assignments can only be set up through the Director software.

Refer to the details that follow while working with any of the listed topics:

More: Provides access to additional screens.

Card: Enter the card version number (if applicable), and the access-card/token number for this user, and select **Ok** when finished.

```
0xx UserName  
↓Ok vv_nnnnnnnnn
```

If card-access (entry at controlled doors) does not apply, leave the card number as "00000000".

Card Version number support is supplied by your Security Representative.

Firmware revisions needed for 9-digit card IDs, or cards with version numbers: Panel firmware ≥ **V3.2**, and door/elevator controller firmware ≥ **V1.5**.

PIN: This allows setting or changing the **Personal ID** Number for this user. (You'll be asked to enter it twice--to help protect against typing errors.)

```
New PIN - - - -  
For User 0xx
```

The last two digits of the PIN must be different. Also, do **not** use consecutive numbers like "1234".

Name: Use the keypad to enter the user's name, and select **Ok** when finished.

```
UserName . . . .  
↓Ok
```

Tip: Check the letters on the numeric keypad. Then, for each letter of the name, press the specific key until the letter appears (e.g., pressing **2** makes a 2, A, B, C; **0** provides 0, Z, _ <space>, Q, etc).

To move to the next letter-position, use the **▶** key, or wait 2 seconds. To retype a previous letter, use the **◀ ▶** keys, and then enter the letter as before.

Aut: Use the **Next** and **Prev** buttons to select an authority profile for the user. (Select **Ok** when finished).

```
0xx AuthProfile  
↓Ok ↓Next ↓Prev
```

This determines what doors the user can enter (and at what time of day), and the tasks they will be able to perform at system keypads.

Setting this as **Undfnd** will delete the user!

User authority profiles themselves are normally set up by your service technician (service PIN needed).

System

/ Condo (Suite Security): For systems with suite security keypads, this screen allows

```
0xx UserName  
↓System ↓Condo
```

accessing the **System** authority screen (same as **Aut**, above), and the **Condo** (Suite Security) authority screen.

```
0xx AuthProfile  
↓Ok ↓Next ↓Prev
```

Tip: Press "X" escape key if you do not want to use this screen.

Use the **Next** and **Prev** buttons to select an authority profile for the user. (Select **Ok** when completed).

Condo (Suite Security) **Authority of "Undfnd":** This is a reserved suite user (that can be edited by a user with suite "Master" authority).

Suite Security Authority assignments for a user are set up through the Director software.

Lang / Chal: This screen allows setting the LCD language for

```
0xx . . Lang:Eng.C:N  
↓Ok ↓Lang ↓Chal
```

this user, and whether or not the "physically-challenged" unlock times and door-held-open times apply to this user.

Select **Lang** to 'toggle' the language, or **Chal** to 'toggle' the "Challenged" setting. When finished, select **Ok**.

Watch the screen for the settings to change. (You will remain in this same screen.)

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).






Deleting a User

Users can be deleted from the system when necessary.

To allow tracking card-usage, you can alternatively leave the user in the system, but set them to an authority profile that provides **no** access to doors or keypads. (See the preceding topic for more info.)

Note: Setting the authority to "undefined" will delete the user (equivalent to selecting **Delete**).

Steps:

1. Log into the keypad by entering your user ID and/or PIN as indicated on-screen.

2. Use the ◀ ▶ left and right arrow buttons to scroll the items until "Users" appears and press Ok.

3. Enter the specific user number (and select **Ok**, or select **Ok** first, and then press ▶ until the desired user appears on-screen.

4. With the desired user on-screen, select **Delete**.

5. Then, select **Yes** to delete the user, or **Cancel** to stop the action.


To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).




Setting the Date and Time

The panel date and time can be set through an LCD keypad if necessary.

"Service Test" authority is required to set the date and/or time.

For a reference of the dates to automatically switch between standard time and daylight-savings time, refer to "Holidays and Time-Change Dates" (in the **Reference** section).

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

2. Use the ◀ ▶ left and right arrow buttons to scroll the items until "Time" appears and press Ok.

3. Enter the current Date and Time.

4. Watch the flashing cursor as you enter the year, month, day, hours, and minutes (2 digits each).
When finished, select **Ok**.

NOTE: Enter the hours as 00-23 (24-hr. clock).

Example: Noon = 12:00, 1PM = 13:00, 2 PM = 14:00 to 11PM = 23:00, Midnight = 00:00, 1 AM = 01:00, 2 AM = 02:00 etc.

You can use the (◀ ▶) keys to scroll back or forward within the date or time as needed.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

Viewing the History

All activity that occurs in the system can be viewed one event at a time. This includes area (alarms) /door activity, as well as the tasks that users have performed at a keypad.

Depending on your system type and licensing permissions, up to 65 536 events will be recorded.

Viewing an area's history requires authority for that area.

Press any of these keys to continue viewing the History.

"T / L" next to the time indicates that the date/time had not been set when the event occurred.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: _ _ _
```

2. Use the ◀ ▶ left and right arrow buttons to scroll the items until **History** appears and press Ok.

```
Menu Options
◀ History ▶ ↓Ok
```

3. Select **All** for a complete list, or **Category** for

history referring to an Area, Condo (Suite Security) keypad, or Application module (e.g., Printer). Press Ok.

```
View History of:
◀ All ▶ ↓Ok
```

4. If you selected Category, select your desired topic (such as by **Area**).

```
View History of:
↓Area ↓Condo ↓App
```

(Condo: Suite Security)

If you selected "All" the area or other item associated with each event will be shown on the screen.

5. If you selected by Area, the arming-level for the first area will be shown, and you can select:

- **Hist**: Shows the log of events for the displayed area;
- **Next Area**: Jumps to the next area.

```
AreaName....Off
↓Hist ↓Next Area
```

6. To cycle through the History press the (◀▶) **right or left arrow** keys. For more details about this event select "...↓".

```
xxx ▶ 1:23pMar
Event Displays ...↓
```

Printing the History Log

If your system includes a printer-capable module, you can print the history log. (This will be sorted by date).

Steps:

1. Ensure the printer is turned on, and has paper loaded.

2. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: _ _ _
```

3. Use the ◀ ▶ left and right arrow buttons to scroll the items until **History** appears and press Ok.

```
Menu Options
◀ History ▶ ↓Ok
```

4. When **Category** appears, press Ok.

```
View History of:
◀ Category ▶ ↓Ok
```

5. Select **App** (Application Module) to access the module with printer functions.

```
View History of:
↓Area ↓Condo ↓App
```

6. Select **SMA** or **HSC** which are other related equipment selections for use by a technician only. However, they will both permit access to the Printer selection.

```
Menu Option
↓SMA ↓HSC
```

7. Select **Printer** to access the printer menu.

```
Select Option...
↓Printer ↓Lang
```

Choose from the following selections:

```
Printer On-Line
↓Pause ↓Cnc ↓Plog
```

- **Start:** Enables the printer (if required).
- **Pause / Resume:** Pauses or resumes a printout;
- **Cnc:** Cancels a printout. **Tip:** You may also need to turn the printer off to clear its memory.
- **Plog:** Prints the entire history log.

To return to the main screen (log out), press the “X” escape key a few times, or let the system time-out (1 minute).

Changing the Printed History Language

You can change the language for the printed history log when needed.

Check with you Security Representative to confirm your system version is capable of this feature.

Steps:

Follow steps 1 to 6 from the previous “Printing the History Log”

7. At step 7, select **Lang** to change the printing language for this application module.

```
Select Option...
↓Printer ↓Lang
```

The present printed language will be indicated on the first line next to "Lang:".

8. Select **Change** to change the language. Press **Ok** when completed.

```
Lang: Language
↓Ok ↓Change
```

To return to the main screen (log out), press the “X” escape key a few times, or let the system time-out (1 minute).

Testing Monitored Sensors (Performing a Walk Test)

A **Walk Test** allows you to test specific sensors (protection points) in the system, to ensure that they are functioning properly.

A walk test can be done by users with "System Test" authority.

A walk test must be completed within 15 minutes.

Emergency points (i.e. smoke, fire alarm, panic, etc.) on a Monitored system, display as Armed and should **not** be tested during a Walk Test. The monitoring station must be notified if these points will be tested. When tested successfully, Emergency points will indicate PASS and Armed will change to Alarm.

"Pass" indicates that an intrusion point is functioning correctly (i.e. the sensor is operating properly), while "Fail" indicates that a problem may exist with that point or that the point was not tripped.

All points except Emergency points may be bypassed during the Review for convenience. Restore any bypassed points before turning protection on or they will reduce system security.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

```
Welcome
Enter ID: _ _ _
```

2. Use the ◀ ▶ left and right arrow buttons to scroll the items until **Test** appears and press Ok.

```
Menu Options
◀ Test ▶ ↓Ok
```

3. When **Area** appears, press Ok.

```
Test?
↓Area ↓System
```

4. Choose from the following selections:

- **Test:** To test the displayed area;
- **Next Area:** To jump to the next area.

```
AreaName . . . . Off
↓Test ↓Next Area
```

5. Select **Walk** to perform a Walk Test of this area.

```
Select test type
↓Walk ↓Holdup
```

6. At this time you can proceed to test the protection points in the selected area (i.e. open doors, walk in front of motion detectors, etc.).

NOTE: If any fire sensors or 24 hour type inputs must be tested and it is a reporting system, the monitoring station must be notified.

The walk test must be completed within 15 minutes.

7. After activating points in the tested area, return to the keypad and select **Review** to view the results of the Walk Test.

```
Area in walk test
↓Review ↓End
```

8. The tested points and the results (Pass/Fail) will be displayed.

```
xxx ▶ ItemName
Status . . . ↓
```

9. Press the "...↓" key to view all points that passed during the test. Another method is to use the ◀ ▶ left and right arrow buttons to scroll through the results of all points tested in the area.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).





Testing Panic Buttons (Performing a Hold-up Test)

A **Hold-up Test** allows you to test "hold-up / panic" devices in the system, to ensure they are functioning correctly.

NOTE: Using the Hold-up test selection will prevent hold-up signals from being transmitted to the monitoring station.


A hold-up test can be done by users with "System Test" authority.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

2. Use the ◀ ▶ left and right arrow buttons to scroll the items until **Test** appears and press Ok.

3. Select **Area**.

4. Choose from the following selections:
 - **Test:** To test the displayed area;
 - **Next Area:** To jump to the next area.
5. Select **Hold-up** to perform a 'hold-up' test of this area.


At this time you can proceed to Test the Hold-up devices in the selected area. Like press in panic buttons, etc.

When activating hold-up devices in the tested area, the system will emit a chime when the hold-up points are activated, if functioning correctly. If no chime is emitted when testing the points, you may need to inquire about it with your Security Representative.

6. Select **End** when finished viewing and/or to select another area to test.






To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

Testing Sirens (System Test)

A **System Test** allows you to test the entire system to ensure security components are functioning properly (sirens, etc.).

UL Listed Systems: This test must be done at least once per week for UL listed systems.

Steps:

1. Enter your user ID and/or PIN to log into the keypad.

2. Use the ◀ ▶ left and right arrow buttons to scroll the items until **Test** appears and press Ok.

3. Select **System**.

4. During the system test, this message will appear.


All Sirens will sound for 5 seconds and all keypad lights will turn on to indicate that the system is functioning correctly.

Please ignore this ChxSum message. It is for technical personnel use.

To return to the main screen (log out), press the "X" escape key a few times, or let the system time-out (1 minute).

Reference Topics

System Information

Your alarm system has specific information. This information should be recorded below at the time of your system's installation.

Contact Information

Security Representative:

Monitoring Station Phone Number:

Your System Number:

When to Contact the Monitoring Station

- When an accidental alarm happens.
- When major work is being done on the premises that could interfere with the alarm.
- If you loose your system number and password.
- When doing a periodic test that may involve testing panic buttons, some sensors or with all the protection turned on.

When to Contact your Security Representative

- If there appears to be a fault with the system.
- To order additional protection equipment for installation. Like, a contact for a new door, smoke sensors, motion detector for a new room addition etc.

Protected Area Names:

Area 1: _____

Area 2: _____

Area 3: _____

Area 4: _____

Area 5: _____

Area 6: _____

Area 7: _____

Area 8: _____

Area 9: _____

Area 10: _____

Area 11: _____

Area 12: _____

Area 13: _____

Area 14: _____

Area 15: _____

Area 16: _____

System Details:

Entry and Exit Delays:

Entry Delay: _____ Exit Delay: _____

Miscellaneous Features:

	Yes	No
Duress PIN entry supported	<input type="checkbox"/>	<input type="checkbox"/>
Entry Delay in Stay	<input type="checkbox"/>	<input type="checkbox"/>
Arm to Stay if Failure to Exit	<input type="checkbox"/>	<input type="checkbox"/>
Terminate Exit Delay	<input type="checkbox"/>	<input type="checkbox"/>
Alarm if Failure to Exit	<input type="checkbox"/>	<input type="checkbox"/>

Emergency Keys that are Available:

	Yes	No
Fire	<input type="checkbox"/>	<input type="checkbox"/>
Police	<input type="checkbox"/>	<input type="checkbox"/>
Emergency (non medical)	<input type="checkbox"/>	<input type="checkbox"/>

Function Key Reference

The Function key (**F**) is pressed and held in while pressing specific number keys for customized functions.

Note: Function keys are not active until they have been added to the system by your Security Representative.

Function keys 1 – 5 can be used by anyone. Function keys 6, 7, 8, 9 and 0 may require a user (with function key authority) to enter their user numbers before they can operate the function keys.

Function Key Assignments:

F + 1 = _____

F + 2 = _____

F + 3 = _____

F + 4 = _____

F + 5 = _____
(also turns "chime" on and off)

F + 6 = _____

F + 7 = _____

F + 8 = _____

F + 9 = _____

F + 0 = _____

Door Chime Feature:

The "Door Chime" feature refers to LCD keypads emitting tones when a perimeter door is opened (while the area is armed to "Stay")--to alert the person(s) inside that someone has entered.

Pressing **F** and **5** simultaneously always toggles the "Chime" feature on and off, and this function key sequence can also be programmed for an additional function if desired.

Residential Fire Safety / Evacuation Plan

No fire detection system should be considered 100 percent foolproof.

This fire alarm system can provide early warning of a developing fire. Such a system, however, does not ensure protection against property damage, or loss of life resulting from a fire. Any fire alarm system can fail to warn for a number of reasons such as: smoke not reaching a detector that is behind a closed door.

When considering smoke alarms for residential applications, refer to NFPA standard 72, "The National Fire Alarm Code", or the equivalent for your area.

The NFPA version is available at a nominal fee, from: The National Fire Protection Association, 1 Batterymarch Park, P.O. Box 9101, Quincy, MA 02269-9101.

Residential Installations

Adherence to the NFPA Standard 72 can lead to reasonable fire safety when the following items are practiced:

- **Minimize Hazards:** Avoid the three traditional fire killers--smoking in bed, leaving children home alone, and cleaning with flammable liquids.
- **Provide a Fire Warning System:** Most fire deaths occur in the home. The majority, during sleeping hours. The minimum level of protection requires working smoke detectors outside each separate sleeping area, and on each additional floor of the dwelling.

Notice: Never try to fight a large fire on your own, and never use water when dealing with a kitchen (grease) fire. (For a small grease fire, use baking soda, or a fire extinguisher that is approved for this.)

Practicing Fire Safety

Fire can grow and spread through your home very quickly. In a typical home fire, you may have as little as two minutes to escape from the time the smoke alarm sounds. Knowing how to use those minutes wisely can make a life-saving difference. That's why home fire escape planning is so important. Developing and practicing a home fire escape plan will help you snap into action immediately if the smoke alarm sounds, so you can get out quickly and safely.

Escape Plan Guidelines:

- Make sure to have *at least* one smoke alarm on each level of the home and in or near each sleeping area. Test the alarms every month by pushing the test button, and replace the batteries once a year or when the alarm chirps, warning that the battery is low. (Note: Newer smoke alarms have a signal repetition pattern of three beeps, followed by a one and a half second pause.) The majority of today's smoke sensors are interconnected with alarm control units (such as this one) and get their power from them.
- When entering other buildings, including other people's homes, ask what type of emergency alarm system is in place. If it sounds, act immediately.
- **Draw a floor plan** of your home, marking all doors and windows, and the location of each smoke alarm. If windows or doors have security bars, equip them with quick-release devices.
- Locate two escape routes from each room. The first way out would be the door and the second way out could be a window.
- As you exit your home, close all doors behind you to slow the spread of fire and smoke.
- If your exit is blocked by smoke or fire, use your second exit to escape. If you must escape through smoke, stay low and crawl under the smoke to safety. Smoke will rise to the ceiling, leaving cooler, cleaner air close to the floor. Crawl on your hands and knees, not belly, because heavier poisons will settle in a

thin layer on the floor.

- If you live in a high-rise building, use the stairs — never the elevator — in case of fire.
- Choose a meeting place a safe distance from your home and mark it on the escape plan. A good meeting place would be a tree, telephone pole, or a neighbour's home. In case of fire, everyone should gather at the meeting place.
- Make sure the street number/address of your home is visible to firefighters.
- Memorize the emergency number of the local fire department. Once outside, call that number immediately from a nearby or neighbour's phone, or use a portable or cellular phone you can grab quickly on the way out.
- Practice your escape drill at least twice a year.
- NEVER go back inside a burning building!

Apartment buildings, dormitories, and high-rises

If you live in an apartment building or dormitory (up to four stories), make sure it's protected by building-wide fire detection and alarm systems, and check with your apartment manager to ensure that those systems are regularly tested and working properly.

If you live in a high-rise, count the number of doors between your apartment and the two nearest exits. If you discover fire, sound the fire alarm and call the fire department. Leave the area quickly, taking your key and closing all doors behind you. If the building has a voice enunciation system, follow its instructions precisely, unless doing so puts you in immediate danger. If fire or smoke blocks your exits, stay in your apartment and cover all cracks and vents (using wet towels, duct tape, linens, clothing, and so forth) where smoke could enter. Telephone the fire department, even if firefighters are already at the building, and tell them where you are. Signal to firefighters for help with a light cloth. If possible, open the window at the top and bottom, but be ready to shut the window immediately.

Messages for young children

To be safe from a fire in your home, you need three things:

1. Smoke Alarms: Make sure you have at least one smoke alarm on each level of your home. A smoke alarm makes a loud noise. When you hear a smoke alarm beep, it's telling you that there is smoke and you need to get out of your home.

Questions: How many of you have a smoke alarm in your home? Have you ever heard your smoke alarm? What does it sound like? Do you know what the smoke alarm is telling you?

2. A Home Fire Escape Plan: Make a home fire escape plan with your parents or the grown-ups in your home. You'll need two ways out of every room. One way out would be the door, and the second way out may be a window. After you make your plan, practice it!

3. A Meeting Place: Pick a place outside your home where everyone will meet after exiting. A good meeting place would be a tree, light or telephone pole, or mailbox.

Arming Station Reference

MONITOR xL™ Arming Station (option)

The optional MONITOR xL Arming Station allows many system tasks to be performed without having to login at the LCD Keypad. The following is an overview of the available commands.

For more information on entering at a controlled door and/or disarming the system, refer to the "Welcome" and "Alarm" chapters.

<login> represents the form of user identification used e.g. badging card and or ID – PIN entry.

Be sure to enter all digits of your user-ID and/or PIN (e.g., 023).

Command	Result
<login> only	Access

(Momentary unlock of a door)

Command	Result
* 1 <login>	Turn Area Off
Command	Result
* 1 0 <login>	Turn all Areas Off

ENSURE ALL PROTECTION POINTS ARE SECURE WHEN ARMING AT THE ARMING STN

If arming to STAY or ON occurs while any number of non-bypassable protection points are insecure, the Arming Station will warn the user with audible and visual indications. The arming station will make a long buzz and the left and right lights will flash back and forth. This will also cause an alarm condition. The user must turn OFF, locate and correct the problem and attempt arming again. If the protection point is bypassable, it will be automatically bypassed when arming is done at the station. Unless specially programmed, all points except the entry/exit door ARE bypassable.

Command	Result
* 2 <login>	Turn area to Stay

Command	Result
* 3 <login>	Turn area On
Command	Result
* 3 0 <login>	Turn all Areas On
Command	Result
* 5 <login>	Door Commands and Disarm area

Door Commands
If area is off and door unlocked, door is locked.
If area is off and door locked, door is unlocked.

Disarm Area
If area is on, door locked and user is authorized, area turns off and door is unlocked.

Command	Result
* 6 <login>	Work Late in area by 2 hours at a time from the current time.

Scheduled area only.
This command can only be used again at the end of the first entered 2 hours when the arming station will indicate closing time again with the work late LED flashing and tones. At that time, this command can be used again to extend the closing time another 2 hours.

Command	Result
* 6 n <login>	Worklate in area for n hrs.

Work Late in this area for " n " hours where n = 1 – 9 hours Scheduled area only.

Command	Result
* 7 <login>	Use Armed light to view area condition for 20 seconds .

Armed light is Green for Area OFF,
Armed light is solid red for Area in STAY
Armed light is flashing red for Area ON.

Command	Result
* 9 <login>	Silence alarm (in all areas)

Command **Result**
*Cancels any keys previously entered.*

Command **Result**
If performing a “*” command with UID/PIN, insert a “#” key between command and UID/PIN entry (e.g. “* 1 # 341 4141 ” for user 341, pin=4141 trying to arm the area: *1).

No Commands (Simple Access)

Door Mode	<Login>	Notes
Card Only	<card>	If a UID/PIN is entered, it will be ignored
Card & PIN	<card> <pin>	UID is not required since the card automatically identifies the <uid>
Card or UID/PIN	<card> or <uid> <pin>	
UID/PIN Only	<uid> <pin>	If card is presented, it will be ignored.

<uid> – User ID


With Commands


Door Mode	*<cmd> <Login>	Notes
Card Only	*<cmd> <card>	If a UID/PIN is entered, it will be ignored
Card & PIN	*<cmd> <card> <pin>	Card badging must always be done before the PIN entry.
Card or UID/PIN	*<cmd> <card> or *<cmd> # <uid> <pin>	Pressing “#” is required between the command and uid/pin entry.
UID/PIN Only	*<cmd> # <uid> <pin>	Pressing “#” is required between the command and uid/pin entry. (Note *<cmd> # <pin> in PIN Only systems)

<cmd> – Command

MONITOR xL Arming Station Lights

The optional MONITOR xL Arming Station has three lights to indicate door, system and arming status. The following list indicates the light messages and audible results from the Arming Station. For detailed information on Keypad Tones, see *MONITOR Keypad Tones*.



This icon  on key 9 is for the command to silence an alarm * 9 <login>

Work Late Light



Yellow light on solid within 15 minutes of the scheduled closing time.

Off if the area is not scheduled or there are more than 15 minutes to the scheduled closing time.

Door State Light



Red light on solid if the door is locked.

Same light solid green if the door is unlocked.

Flashing red while protection turning off if there was an alarm in the area.

Armed Light



On solid green if the area is disarmed (Off).

On solid red if the area is set to the "Stay" arming-level (only the perimeter sensors being monitored).

Flashing red if the area is armed (On)

Tone/Siren

Result

Entry / Exit Tones

Quick turning on and off beep.

Fire Siren

A repeating tone that turns on for 5 seconds off for 5 seconds. After this happens 3 times there is a delay and the same sequence repeats.

Burglary Siren

Continuous tone

Bad Command

Double short beeps

Command Accepted

Single long beep

Not authorized to Perform Command

Double long beep

Wireless Keypad Reference

MONITOR xL Wireless Keypad (option)

The optional MONITOR xL Wireless Handheld Keypad allows system commands to be performed using the wireless keypad. Below is a list of the available Wireless Keypad commands, and their proper Key sequences.

“login” refers to entering your User ID and PIN.

Command	Result
<i>“login”</i> + command key +1	<i>Turns area fully Off</i>

Command	Result
<i>“login”</i> + command key +2	<i>Turns area to Stay</i>

Command	Result
<i>“login”</i> + command key +3	<i>Turns area fully On</i>

Command	Result
<i>“login”</i> + command key +4	<i>Performs a System Test</i>

All Sirens will sound and all lights turn on for 5 seconds to indicate that the system is functioning correctly.

Command	Result
<i>“login”</i> + command key +9	<i>Clears or Silences Alarms</i>

Command	Result
<i>“login”</i> + function key +1 to 9	<i>Activates selected function key</i>

Command	Result
*	<i>Cancels any keys entered</i>

Error Messages and Trouble Indications

Keypad Screen Display Error Messages

This section contains a list of error messages that may appear on the keypad's display screen. The condition responsible for each message is explained below.

Power Failure: AC Failure.

System Trouble: Control Unit or Module Tamper condition, module Communications failure, Fuse Failure.

Battery Trouble: Low voltage from Control Unit or module battery or missing/disconnected.

Phone Trouble: Trouble with Communications to the monitoring station.

Report Trouble: Trouble with Communications to the monitoring station.

Area in Test: Walk Test or Hold-up Test In-Progress.

Program Lost: Alarm System Operations Configuration Lost.

Program Error: Error in Alarm System Configuration on Control Unit, Error in Configuration on module.

HSC Comms: Alarm Communications Trouble.

If a trouble condition persists, contact your Security Representative to investigate.

Keypad Yellow Trouble Light

The Yellow Trouble Light on the keypad may turn on when the following system conditions occur:

System Tamper, Battery Trouble, AC Failure (Flashing), Phone Line Trouble, Report Delay, Time Lost, Time Changed, Program Error, Fuse Trouble, Module Trouble, Module Program Error, Misc. (Test Failure), HSC Trouble.

System Status Trouble

The following conditions may appear when viewing the system status:

System Tampr,
LoNoBattery,
AC Failure,
No PhoneLine,
Report Delay,
Time Lost,
Time Change,
Program Edit,
Prog Error,
Fuse(s) Fail,
Pod Trouble,
Pod Battery,
Pod ProgEdit,
Pod ProgErr,
HSC (alarm communications) Trouble

"POD" refers to a "Module". (Protection Point expander, door controller, keypad, etc.).

If any of these trouble conditions persist, contact your Security Representative to investigate.

Things to Do to Prevent False Alarms

Please do your part to prevent false alarms. This ensures that authorities will take your emergency seriously.

- Familiarize yourself with the control unit. Carefully read and review your operator's manual or user guide. If there is anything you do not understand, contact your Security Representative to explain it further.
- Enter and leave only through predefined Entry/Exit Routes.
- Do not turn the protection on with people on the premises; unless, you select STAY to only turn the perimeter protection on.
- Check the protected area to make sure all doors are closed and no one is left inside before turning on the protection.
- Always have your system number and pass number ready when calling the monitoring station.
- Keep your system number and pass number confidential.
- Notify the monitoring station if you did not turn the protection off before the "entry time" countdown expires.
- Notify the monitoring station immediately if someone accidentally activates a panic button or emergency key.
- Notify the monitoring station immediately if you have accidentally caused a false alarm.
- Notify the monitoring station before performing a live test. E.g. pushing emergency keys or causing detection devices to alarm with protection turned on.
- Request service from your Security Representative in the event of an unexplained alarm or any system problems.
- Explain the system's operation in detail to any new user.
- Do not leave pets on protected premises when the protection is fully ON, unless the system was planned for it.
- Quickly repair any damaged doors or windows that have excessive play or do not lock.
- Do not place space heaters, moving objects or leave windows open in the path of motion detectors when protection is on.

Index

Access Token ON, OFF.....	11	False Alarm Prevention.....	39
ACPO Confirmed Alarm Remote Reset.....	12	Faulty sensor, bypassing	15
ACPO Resetting Confirmed Alarms.....	11	Fire safety	32
ACPO Restoring Tamper.....	12	Function keys	
Activity logs.....	25, 26	Using.....	14
Adding		Function Keys	
Users	20	Reference.....	31
Adding a User	20	Group of Areas protection On	10
Administration and maintenance tasks	19	History, printing	26
Alarm monitoring features.....	6	History, viewing.....	25
Alarms		Holdup test.....	28
Dealing with	7	ID number, PIN number	3, 11, 12
Area arm/disarm status.....	9	Keypad and Access Token ON, OFF	11
Area Groups protection On.....	10	Keypad Chime Tones:.....	6
Areas, individual protection On	10	Keypad entry basics.....	4
Arming	9	Keypad Error Messages.....	38
Arming Station Reference.....	34	Keypad Lights, Buttons	2
Audible Tones.....	6	Keypad Tones.....	6
Authority Abilities	20	Keypad, wireless	37
Beeping (what to do if the keypad is beeping	7	Language for the printed history logs	26
Bypassing a faulty sensor	15	Lights on an Arming Station	36
Cancelling A False Alarm.....	7	Maintenance tasks	19
Changing settings for		Monitor Keypad Tones	
Users	22	Arming and Disarming.....	6
Changing Your Own PIN.....	20	Burglar Alarm	7
Check status or control		Entry and Exit Delay.....	6
Elevator Readers	17	Error and Warning Tones	6
Monitored sensors (input points).....	15	Fire Alarm.....	6
Chime Door Feature	31	Trouble.....	6
Control and status features.....	14	Monitoring Station, when to contact	30
Controlling doors.....	16	OFF, Protection.....	10
Copyrights and Trademarks.....	ii	ON, OFF, Access Token and Keypad.....	11
Date and Time for the panel, setting.....	24	ON, STAY	9
Deleting users.....	24	Panic buttons, testing (holdup test).....	28
Disarming.....	10	Performing Other Functions	3
Disclaimers	ii	PIN	
Doors		Reverse digits to indicate duress	3
Check status	16	PIN number, ID number	3, 11, 12
Controlling.....	16	PIN, changing.....	20
Duress Alarm	3	Point (sensor), bypassing.....	15
Elevator readers		Points (sensors), checking the status of.....	15
Checking status or controlling.....	17	Printer	17
Emergency keys		Printing the History.....	26
Using.....	8	Protection OFF.....	10
Error Messages	38	Protection ON, STAY	9
Evacuation plan	32	Readers, check status or controlling	16
Event logs.....	25, 26	Schedules	
False Alarm		Adjusting	8
Cancelling	7	Suspending.....	9

Security Representative, when to contact.....	30
Sensor, bypassing	15
Sensors (points), checking the status of	15
Setting the Date and Time	24
Setting, Unsetting the Alarm	9
Siren	7
Sirens.....	7
Sirens, testing	28
Status and control	
Application module (Printer).....	17
Checking sensors (points).....	15
Checking the status of doors.....	16
Elevator readers.....	17
Monitored sensors (input points).....	15
Status and control features	14
Status of System, Checking.....	14
STAY, ON	9
Suspending schedules.....	9
System information (areas, authorities, etc.....)	30
System test.....	28
Testing sirens.....	28
Testing the Entire System.....	28
Testing the System	
Panic buttons (holdup test)	28
Walk Test.....	27
Time and date for the panel, setting.....	24
Trademarks and copyrights.....	ii
Trouble Light Indications.....	38
Trouble messages	38
Unlock/relock doors	16
Users	
Adding.....	20
Deleting.....	24
View or Edit.....	22
Using Emergency keys	8
View area arm/disarm status.....	9
Viewing	
User settings	22
Viewing the History	25
Voice Siren.....	7
Walk Test.....	27
When to contact the Monitoring Station	30
When to contact your Security Representative	30
Wireless keypad.....	37
Work-late.....	8

